

Central Power Plant

123 Good St.
GoodTown, CT 06111

Thursday, May 31, 2007

HRSG 3 Daily Report

GT 3 Daily Report

Date/Time	Inlet Temp (DegF)	Exhaust Temp (DegF)	Feedwater Flow (KPPH)	Econ Temp In (DegF)	Econ Temp Out (DegF)	Superheat Steam Press (PSI)	Superheat Steam Temp (DegF)	Superheat Steam Flow (KPPH)	Oil Fuel In (GPM)	Gas Fuel In (KSCF)	Sat Steam Flow (KPPH)	GT Oil Fuel Flow (GPM)	GT Gas Fuel Flow (KSCFH)	GT Inlet Temp (DegF)	GT Outlet Temp (DegF)	Nox Flow (#/SEC)	Augment Flow (#/SEC)	Gen Power (MW)	Gen Voltage (KVOLT)	Gen Freq (Hertz)	Gen Reactive Power (MVAR)	Generator Power Factor (PF)
5/31/2007 1:00	835.6	382.1	41.8	95.7	330.9	252.0	524.0	2.2	0.0	29.0	38.4	0.0	49.7	74.4	835.6	0.7	0.0	2.6	4.1	60.0	1.1	0.9
5/31/2007 2:00	837.6	382.1	41.0	95.5	331.0	252.0	523.8	2.3	0.0	28.7	38.3	0.0	49.7	73.6	837.6	0.7	0.0	2.6	4.1	60.0	1.1	0.9
5/31/2007 3:00	831.4	382.1	40.1	95.0	331.3	252.5	523.9	2.2	0.0	29.3	38.7	0.0	49.0	72.7	831.4	0.7	0.0	2.6	4.2	60.0	1.2	0.9
5/31/2007 4:00	825.6	382.7	38.4	95.0	331.9	252.4	523.8	2.2	0.0	28.9	37.7	0.0	49.0	68.4	825.6	0.7	0.0	2.6	4.2	60.0	1.1	0.9
5/31/2007 5:00	824.8	382.8	40.9	94.3	332.0	251.9	523.0	2.3	0.0	28.8	37.7	0.0	50.3	66.9	824.8	0.7	0.0	2.6	4.1	60.0	1.2	0.9
5/31/2007 6:00	827.6	382.9	40.9	93.7	331.6	252.2	523.6	2.3	0.0	29.5	38.5	0.0	50.6	64.2	827.6	0.7	0.0	2.7	4.1	60.0	1.2	0.9
5/31/2007 7:00	849.6	382.5	42.2	93.4	331.1	252.2	523.4	2.4	0.0	29.4	39.2	0.0	51.8	64.9	849.6	0.7	0.0	2.9	4.1	60.0	1.3	0.9
5/31/2007 8:00	882.0	381.7	41.8	94.2	329.5	252.6	523.5	2.5	0.0	29.4	40.4	0.0	54.2	68.2	882.0	0.8	0.0	3.2	4.1	60.0	1.4	0.9
5/31/2007 9:00	901.8	381.8	46.1	98.8	326.8	252.7	529.1	2.6	0.0	32.1	43.4	0.0	55.9	72.3	901.8	0.8	0.0	3.3	4.1	60.0	1.4	0.9
5/31/2007 10:00	937.2	382.5	49.3	101.4	321.9	253.7	539.6	2.8	0.0	37.3	48.3	0.0	56.8	77.5	937.2	0.8	0.0	3.5	4.1	60.0	1.5	0.9
5/31/2007 11:00	970.7	384.2	53.9	98.7	319.4	254.2	546.1	2.9	0.0	39.1	51.8	0.0	62.1	80.5	970.7	0.9	0.0	3.6	4.2	60.0	1.6	0.9
5/31/2007 12:00	974.8	385.6	53.7	97.6	318.7	253.4	548.7	3.0	0.0	40.0	52.9	0.0	65.6	81.1	974.8	0.9	0.0	3.7	4.2	60.0	1.6	0.9
5/31/2007 13:00	967.3	385.9	55.5	98.6	318.5	254.0	551.4	2.9	0.0	42.7	53.9	0.0	65.1	80.8	967.3	0.9	0.0	3.7	4.2	60.0	1.6	0.9
5/31/2007 14:00	967.4	386.0	53.8	100.9	318.8	254.6	550.1	2.9	0.0	41.2	52.5	0.0	65.0	79.1	967.4	0.9	0.0	3.6	4.2	60.0	1.6	0.9
5/31/2007 15:00	900.4	387.8	52.0	100.4	322.7	254.0	546.6	2.9	0.0	40.7	51.4	0.0	63.5	54.5	900.4	0.9	0.0	3.7	4.2	60.0	1.6	0.9
5/31/2007 16:00	897.6	387.7	54.1	100.4	322.4	254.4	547.7	2.8	0.0	41.9	51.4	0.0	62.7	55.2	897.6	0.9	0.0	3.6	4.2	60.0	1.5	0.9
5/31/2007 17:00	875.4	386.7	53.5	102.0	322.4	254.0	546.8	2.8	0.0	42.3	51.1	0.0	59.1	55.0	875.4	0.8	0.0	3.5	4.2	60.0	1.4	0.9
5/31/2007 18:00	849.2	386.8	52.2	101.6	323.4	254.5	546.3	2.6	0.0	41.7	48.9	0.0	54.6	55.1	849.2	0.8	0.0	3.2	4.2	60.0	1.3	0.9
5/31/2007 19:00	838.3	385.5	48.9	98.9	325.7	253.2	540.0	2.4	0.0	37.9	45.4	0.0	51.2	64.3	838.3	0.7	0.0	2.8	4.2	60.0	1.2	0.9
5/31/2007 20:00	833.4	384.7	45.0	102.0	326.3	252.5	537.6	2.3	0.0	35.5	43.9	0.0	50.0	70.8	833.4	0.7	0.0	2.7	4.2	60.0	1.2	0.9
5/31/2007 21:00	823.5	385.5	47.0	103.3	325.5	253.8	542.2	2.1	0.0	37.6	45.4	0.0	48.9	69.0	823.5	0.7	0.0	2.6	4.1	60.0	1.1	0.9
5/31/2007 22:00	824.5	384.6	43.3	100.6	327.2	253.3	536.0	2.2	0.0	34.9	42.8	0.0	49.4	67.7	824.5	0.7	0.0	2.6	4.2	60.0	1.1	0.9
5/31/2007 23:00	820.3	383.8	44.1	96.6	329.1	253.1	530.4	2.3	0.0	33.2	41.2	0.0	49.4	67.1	820.3	0.7	0.0	2.6	4.2	60.0	1.1	0.9
6/1/2007	821.3	383.7	41.7	100.9	330.3	253.0	527.9	2.3	0.0	30.4	39.5	0.0	49.8	63.4	821.3	0.7	0.0	2.7	4.2	60.0	1.2	0.9
Total			1,121					60	0	841	1056	0.0	1,312.0			65.5	0.0	7.1				